

KEY

TWENTY MINS FIRE RESISTANT WITH SMOKE SEALS # INTUMESCENT STRIP

HALF HOUR FIRE RESISTANT WITH SMOKE SEALS & INTUMESCENT STRIP

ONE HOUR FIRE RESISTANT WITH SMOKE SEALS & INTUMESCENT STRIP

VISION PANEL

FANIC BAR

SELF CLOSING SCA SELF CLOSING AUTOMATIC RELEASE

FUSIBLE LINK

DOOR SELECTOR

ILLUMINATED EMERGENCY FITTING WITH RUNNING PERSON SYMBOL & ARROW

NON MAINTAINED EMERGENCY FLOOD LIGHTING CAW BATTERY PACK

S13 'FIRE DOOR KEEP SHUT' 10mm LETTERS TO BOTH SIDES OF DOOR LEAF

FIRE DOOR KEEP LOCKED' TOmm LETTERS TO BOTH SIDES OF DOOR LEAF

FIRE ESCAPE KEEP CLEAR! I Omm LETTERS TO BOTH SIDES OF DOOR LEAF

RUNNING PERSON SYMBOL # ARROW

525 'PUSH BAR TO OPEN' 20mm LETTERS DIRECTIONAL ARROW (GREEN)

526 FIRE RESISTING GLAZING ELEMENT

AREA COVERED BY ESCAPE LIGHTING TO BS.526G, PART I

AREA COVERED BY SMOKE DETECTOR

AREA COVERED BY HEAT DETECTOR FIRE ALARM CALL POINT

FAP FIRE ALARM CONTROL PANEL

FIRE ALARM BELL/SOUNDER

CARBON DIOXIDE FIRE EXTINGUISHER

9 LITRE WATER FIRE EXTINGUISHER

DRY POWDER FIRE EXTINGUISHER

FOAM FIRE EXTINGUISHER

FIRE BLANKET

ALL WALLS AND PARTITIONS TO BE MINIMUM HALF HOUR FIRE RESISTANCE.

EMERGENCY LIGHTING TO COMPLY WITH 2005 EDITION OF BS 5266 PART 1.

FIRE SAFETY RELATED SIGNS AND NOTICES TO COMPLY WITH THE HEALTH AND SAFETY (SAFETY SIGN AND SIGNAL) REGULATIONS

FIRE ALARM AND DETECTION SYSTEM TO BE INSTALLED TO BS 5839 PART | 2002

FIRE FIGHTING EQUIPMENT TO COMETY WITH BS 530G WALL AND CEILING LINNOS ARE TO BE CLASS I SURFACE SPEED OF FLAME (AS DEFINED BY BS 476 FART 7) IN FUBLIC AREAS AND CLASS 0 IN ESCAPE ROUTES.

UPHOLSTERED SEAT FURNITURE TO SATISFY THE FOLLOWING

IGNITION SOURCE (GIGARETTE TEST)
AS SPECIFIED IN S. SESSE PART I
PIRE TEST FOR FURNITURE METHODS
OF TEST FOR THE IGNITABILITY BY
SMOKERS.
BS 5852 PART 2 PIRE TEST FOR
FURNITURE - METHODS OF TEST FOR
THE IGNITABILITY OF UPHOLSTERD
COMPOSITES FOR TESTING BY
FILAMING SOURCE, MINIMUM TEST TO
BE GREI IGNITION SOURCE.

FABRICS THAT HAVE HAD A FLAME RETARDANT TREATMENT TO PASS THE WAITER SOAK IEST AS DEFINED BY BS SGS I TEST CREMIFICATE TO BE SUBMITTED TO FIRE AUTHORITY.

CURTAINS AND DRDAPES TO SATISPY TYPE B PERFORMANCE REGUIREMENTS TO BS 5867 PART 2.

ARTIFICIAL FOLIAGE AND DECORATIVE EFFECTS TO BE FIRE RETARDANT TO THE SATISFACTION OF THE FIRE AUTHORITY.



JD WETHERSPOON PLC

PUB NO: 7668 UNIT F4, WHITELEY SHOPPING CENTRE FAREHAM

PROPOSED LICENSING LAYOUT

FEB 2025 A2/1:100 AKS 7918 L-01

